

DALLAS LABORATORIES, INC.

Consultants and Technologists
Chemical and Petroleum Chemists

P.O. BOX 152837, DALLAS, TEXAS 75315
1323 WALL ST, DALLAS, TEXAS 75215
PHONE 214/565-0593
FAX 214/565-1094

MEMBERS
AMERICAN CHEMICAL SOCIETY
ASTM INTERNATIONAL
AMERICAN SOCIETY OF MATERIALS

MEMBERS
AMERICAN NATIONAL STANDARDS INSTITUTE
AMERICAN SOCIETY FOR QUALITY CONTROL
FEDERATION OF SOCIETIES FOR COATINGS TECHNOLOGY

Submitted by: Advanced Heat Exchange
2995 LBJ Frwy., Suite 224
Dallas, TX 75234

Date: September 24, 2009

Attn: Chuck Armstrong

Report No: 41694-H

REPORT

Lab Sample No.

41694 Cement Board (1/2")


PROCEDURE

Sample was tested for moisture content per ASTM D1037.

RESULTS

<u>Test</u>	<u>Sample</u>
Moisture Content by Weight, % (ASTM D1037)	4.5

DALLAS LABORATORIES, INC.


Kevan W. Jones, Vice President

Analyst: TL, KJ
KWJ: JS