

# DALLAS LABORATORIES, INC.

Consultants and Technologists  
Chemical and Petroleum Chemists

P.O. BOX 152837, DALLAS, TEXAS 75315  
1323 WALL ST, DALLAS, TEXAS 75215  
PHONE 214/565-0593  
FAX 214/565-1094

MEMBERS  
AMERICAN CHEMICAL SOCIETY  
ASTM INTERNATIONAL  
AMERICAN SOCIETY OF MATERIALS

MEMBERS  
AMERICAN NATIONAL STANDARDS INSTITUTE  
AMERICAN SOCIETY FOR QUALITY CONTROL  
FEDERATION OF SOCIETIES FOR COATINGS TECHNOLOGY

Submitted by: Advanced Heat Exchange  
2995 LBJ Frwy., Suite 224  
Dallas, TX 75234

Date: September 24, 2009

Attn: Chuck Armstrong

Report No: 41694-I

## REPORT

### Lab Sample No.

41694 Cement Board (1/2")

## PROCEDURE

Sample was tested for tensile strength per ASTM D1037.

## RESULTS

### Test

Tensile Strength, psi  
(ASTM D1037, Avg. of 5 specimens)

### Sample

1,067  
(SD: 281)

SD – Standard Deviation

DALLAS LABORATORIES, INC.



Kevan W. Jones, Vice President

Analyst: TL, KJ  
KWJ: JS